



Committed to Purity



Regd. Add.: 175, V-Mall, Near Sai Dham, W.E. Highway, Kandivali (E), Mumbai-400101.



+91 22 42974397 +91 22 40103917



sales@bepuretech.com



www.bepuretech.com

CERTIFICATE OF ANALYSIS

1. PARTICULAR OF SAMPLE SUBMITTED

NAME OF PARTY :- M/s.M. K. High school
NATURE OF SAMPLE :- PURIFIED WATER
REFERENCE NO. :- PRI/72
QUANTITY :- 1000 ML

CERTIFICATE NO. 72

SAMPLE RECEIVED DATE :- 31/07/2024

2. RESULT OF ANALYSIS

PARAMETERS	RESULT OBTAINED	UNIT	DESIRABLE LIMITS AS PER IS 10500:2012
CHEMICAL EXAMINATION			
pH	7.6		6.5 – 8.5
Colour	<1	Hazen Unit	5
Odour	Normal	--	Unobjectionable
Turbidity	NIL	NTU	5
Total Dissolved Solid	76	Mg/Lit.	Max. 500
Chloride	30	Mg/Lit.	Max. 250
Alkalinity to Methyl Orange	30	Mg/Lit.	Max. 200
Total Hardness	35	Mg/Lit.	Max. 200
Calcium as Ca	5	Mg/Lit.	Max. 75
Magnesium as Mg.	<5	Mg/Lit.	Max. 30
Iron	NIL	Mg/Lit.	Max. 0.3

REMARK: - This water is Suitable for Drinking purpose.

Q.C. In Charge

DATE: 02/08/2024

