

To,  
The Chief Fire Officer,  
Mumbai Fire Brigade,  
Mumbai.

## FORM B

[See section 3(3) and rule 4(2) ]

Six monthly certificate to be given for Period **1<sup>ST</sup> Jan 2024 to 30<sup>TH</sup> Jun 2024** For compliance of the  
Fire Prevention and Life Safety Measures.

## CERTIFICATE

Ref: - NE/JAPY/G01/2024

Certified that We have carried out inspection of the Fire prevention and Life Safety Measures installed in the  
following premises, namely-

**MR. JAYESH P. YAGNIK.**

Hon. Secretary Borivali Education Society.  
M.K.High School Compound, F.P.NO-129, T.P.S-III,  
Factory Lane, Borivli West, Mumbai-400092.

I / We further certify that these installations in the above mentioned buildings are maintained in good repair  
and efficient conditions during the period **1<sup>ST</sup> Jan 2024 to 30<sup>TH</sup> Jun 2024** as required under the provisions of the  
Maharashtra Fire Prevention and Life Safety Measures Act, 2006 (Mah. III of 2007). The details of the inspection  
of installations carried out by us are mentioned in the report appended herewith In Annexure - I

Place: Mumbai

Date: 29/07/2024

License No: MFS/LA/RF-30

License No: MFS/LARD-29

**NIKHIL  
PRADIP  
SURVE** Digitally signed  
by NIKHIL  
PRADIP SURVE  
Date: 2024.08.07  
20:08:32 +05'30'

Encl: Appendix I - Report

---

APPENDIX- I  
REPORT FOR FIRE FIGHTING SYSTEM

Details of Testing-

Sr.No	Description Of Work	Qty	Remarks
01	Main Hydrant Pump@50HP	01	Working Properly
02	Main Sprinkler Pump@50HP	01	Working Properly
03	Standby Main Pump@50HP	01	Working Properly
04	Jockey Pump@7.5HP	02	Working Properly
05	Booster Pump @ 5 HP	04	Working Properly
06	63mm RRL Delivery Hose	28	OK
07	Double Hydrant Valve(Wet Raiser System)	28	Working Properly
08	Single Hydrant Valve	08	Working Properly
09.	Single Door Hose Box accommodate with 1 no of 15m Hose & Branch Nozzle.	08	OK
10.	First Aid Hose Reel with 30m Thermoplastic Hose Pipe.	28	Working Properly
11.	Sprinkler	600	Working Properly
12.	Conventional Fire Alarm Panel	04	Working Properly
13.	Smoke Detector	400	Working Properly
14.	Manual call point Combined with Hooter	28	Working Properly
15.	ABC Fire Extinguishers Capacity-6kg	34	OK
16.	Main Electrical Pump Control Panel	01	Working Properly
17.	Fire Bucket	16	OK

Place: Mumbai

Date: 29/07/2024

License No: MFS/LA/RF-30

License No: MFS/LARD-29

NIKHIL  
PRADIP  
SURVE

Digitally signed  
by NIKHIL  
PRADIP SURVE  
Date: 2024.08.07  
20:09:04 +05'30'



**Govt. of Maharashtra**  
**Directorate of Maharashtra Fire Service**  
Vidyanagri, Hans Bhugra Marg, Santacruz (East),  
Mumbai – 400 098, Tel-022-26677555, Fax-022-26677666  
www.mahafireservice.gov.in

**FORM N**  
**[ ( See section 9 (3) and rule 14 ]**  
**License to act as a License Agency for the purpose of**  
**Fire Prevention and Life Safety Measure**

License No. MFS / LA / RF-30 / RD-29

Date: 13.01.2024

License is hereby renewed under the provisions of sub-section (3) of section 9 of the Maharashtra Fire Prevention and Life Safety Measure Act, 2006 (Mah. III of 2007) to **M/s. Nexus Engineering** having their registration office at **201, Crystal height, Madhavdas Pasta Rd, Dadar (E), Mumbai 400014** and their contact details are Office Number: 9987661810 and Email ID: nikhil.surve@nexusengineering.in with PAN registration No. CODPS0050K and GST No. 27CODPS0050K1ZW to act as a License Agency for the purpose of the said Act for execution of the fire prevention and life safety measures in relation to

- 1. Fire Fighting and Sprinkler System:** Class D
- 2. Detection and Fire Suppression System:** Class D

**M/s. Nexus Engineering** shall not issue Form A or Form B under sub-section (3) of section 3 regarding the compliance of the fire prevention and life safety measures or maintenance thereof in good repair and efficient condition, without there being actual such compliance or maintenance failing which license granted / renewed shall be suspended or cancelled as per sub section (4) of section 9 and shall be liable for penalty under section 36 of the Act.

Subject to the provision of sub section (4) of section 9 of the said Act and rule 14 of the Maharashtra Fire Prevention and Life Safety Measures Rules, 2009, the license will be valid for a period from **13.01.2024 to 12.01.2026**

**Hatyal Kiran**  
Asst Director  
Digitally signed by Hatyal Kiran  
Date: 2024.01.15  
22:01:41 +05'30'

**Nikhil Pradip Surve**  
Digitally signed by Nikhil Pradip Surve  
Date: 2024.01.15  
20:59:34 +05'30'

**Santosh Shridhar Warick**  
Digitally signed by Santosh Shridhar Warick  
Date: 2024.01.16  
09:10:15 +05'30'

**( S S Warick )**  
**Director**  
**Maharashtra Fire Service**

Digital Signature of Authorized Person to sign Form A or Form B

Note:

\* in absence of digital sign of license holder (responsible to issue Form A or Form B) the license will be treated as invalid.